Utah Department of Environmental Quality
Division of Drinking Water
Public Water System Inventory Report

PWS ID: UTAH12004 **Name:** EUREKA TOWN

Legal Contact EUREKA **Rating:** Approved
LYNN R ELLIOTT **Rating Date:** 09/12/1986

Address: PO BOX 156 **Activity Status:** Active
EUREKA, UT 84628

Phone Number: 435-433-6915
City Served (Area):
County: JUAB COUNTY

 Gal/Day Gal/Min

System Type: Community **Last Inv Update:** 09/16/2009 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 05/22/2008 **Total Dsgn Cap:**
Population: 805 **Surveyor:** ELDEN L OLSEN **Total Emerg Cap:**
 Oper Period: 1/1 to 12/31

Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	ELLIOTT, LYNN R		435-433-6915	435-433-2033	

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Metered	0	303
			303 **Total Svc Connections**

Storage

Total Storage: 500,000 GAL **Number of Units:** 1 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	500,000 GAL	Steel		A	

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
			No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	BLUE ROCK WELL	Active	WL	8	79 GPM	75 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	EUREKA HILL WELL	Active	WL	6	79 GPM	75 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	VULCAN WELL	Active	WL	8	79 GPM	75 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS004	DOLINER WELL #3	Active	WL	8	150 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS005	EAGLE WELL	Active	WL	8		75 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS006	EUREKA HILL REP WELL	Inactive	WL			75 GPM	Yes	GW	Other		
WS007	TINTIC JUNCTION WELL 1	Inactive	WL				Yes	GW	Other		
WS008	TINTIC JUNCTION WELL 2	Active	WL		280 GPM	460 GPM	Yes	GW	Permanent	1/1 to 12/31	

Reports measured flow for wells, approved design capacity for all other sources.